



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Otsego Northern Catskills BOCES

Project Name: Roxbury Schools

Joshua Reiss  
31 Center Street  
Oneonta, NY 13820

Project / PO Number: 17-00954  
Received: 10/05/2016 09:44  
Reported: 11/20/2016 14:00

Analytical Testing Parameters

Client Sample ID: S-1 Kitchen Sink  
Lab Sample ID: J6J0568-01  
Sample Type: Grab

Collected By: Customer  
Collection Date: 09/22/16  
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.00100	0.0150	0.00100	mg/L		11/10/16 2116	11/15/16 1231

Analytical Testing Parameters

Client Sample ID: S-2 Dishroom Sink w/ Sprayer  
Lab Sample ID: J6J0568-02  
Sample Type: Grab

Collected By: Customer  
Collection Date: 09/22/16  
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00330	0.0150	0.00100	mg/L		11/10/16 2116	11/15/16 1231

Analytical Testing Parameters

Client Sample ID: S-3 Dishroom Faucet Sanitizer  
Lab Sample ID: J6J0568-03  
Sample Type: Grab

Collected By: Customer  
Collection Date: 09/22/16  
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00332	0.0150	0.00100	mg/L		11/10/16 2116	11/15/16 1232



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Analytical Testing Parameters

Client Sample ID: S-4 Kitchen Restroom Sink
Lab Sample ID: J6J0568-04
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1233

Analytical Testing Parameters

Client Sample ID: S-5 Coaches Office Bathroom Sink
Lab Sample ID: J6J0568-05
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00760, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1233

Analytical Testing Parameters

Client Sample ID: S-6 Girls Locker Room Sink
Lab Sample ID: J6J0568-06
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00135, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1234



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Analytical Testing Parameters

Client Sample ID: S-7 Coach Faraci's Bathroom Sink
Lab Sample ID: J6J0568-07
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00209, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1235

Analytical Testing Parameters

Client Sample ID: S-8 Room #122 Sink
Lab Sample ID: J6J0568-08
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1235

Analytical Testing Parameters

Client Sample ID: S-9 Room #124 Sink
Lab Sample ID: J6J0568-09
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1236



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Analytical Testing Parameters

Client Sample ID: S-10 Room #103 Sink
Lab Sample ID: J6J0568-10
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1237

Analytical Testing Parameters

Client Sample ID: S-11 Room #103 Bathroom Sink
Lab Sample ID: J6J0568-11
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00180, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1239

Analytical Testing Parameters

Client Sample ID: S-12 Room #109 Faraci
Lab Sample ID: J6J0568-12
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1240



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Analytical Testing Parameters

Client Sample ID: S-13 Room #109 Bathroom
Lab Sample ID: J6J0568-13
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1240.

Analytical Testing Parameters

Client Sample ID: S-14 Room #117
Lab Sample ID: J6J0568-14
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1241.

Analytical Testing Parameters

Client Sample ID: S-15 Nurse's Icemaker
Lab Sample ID: J6J0568-15
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00170, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1242.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Analytical Testing Parameters

Client Sample ID: S-16 First Floor Old Boys Bathroom
Lab Sample ID: J6J0568-16
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00532, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1242

Analytical Testing Parameters

Client Sample ID: S-17 Room #244 Home Ec. Green
Lab Sample ID: J6J0568-17
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1243

Analytical Testing Parameters

Client Sample ID: S-18 Room #244 Home Ec. Yellow
Lab Sample ID: J6J0568-18
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1243



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Analytical Testing Parameters

Client Sample ID: S-19 Room #202 Bathroom
Lab Sample ID: J6J0568-19
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1244

Analytical Testing Parameters

Client Sample ID: S-20 2R Staff Bathroom
Lab Sample ID: J6J0568-20
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2116, 11/15/16 1245

Analytical Testing Parameters

Client Sample ID: S-21 Room #240 Bathroom
Lab Sample ID: J6J0568-21
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00431, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1248



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Analytical Testing Parameters

Client Sample ID: S-22 2R Girls Bathroom
Lab Sample ID: J6J0568-22
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 07:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00369, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1248

Analytical Testing Parameters

Client Sample ID: S-23 Room #116 Bath
Lab Sample ID: J6J0568-23
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00139, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1250

Analytical Testing Parameters

Client Sample ID: S-24 Room #111 Griffi
Lab Sample ID: J6J0568-24
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00137, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1251





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Analytical Testing Parameters

Client Sample ID: S-25 Room #111 Bathroom
Lab Sample ID: J6J0568-25
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00126, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1251

Analytical Testing Parameters

Client Sample ID: S-26 Room #107 Riley
Lab Sample ID: J6J0568-26
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00198, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1252

Analytical Testing Parameters

Client Sample ID: S-27 Room #107 Bathroom
Lab Sample ID: J6J0568-27
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00148, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1253



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Analytical Testing Parameters

Client Sample ID: S-28 Room #218 Erin Lyke
Lab Sample ID: J6J0568-28
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1256

Analytical Testing Parameters

Client Sample ID: S-29 Room #221
Lab Sample ID: J6J0568-29
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1257

Analytical Testing Parameters

Client Sample ID: S-30 First Floor Old Unisex Bathroom Near Main
Lab Sample ID: J6J0568-30
Sample Type: Grab

Collected By: Customer
Collection Date: 09/22/16
Collection Time: 06:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00221, 0.0150, 0.00100, mg/L, 11/10/16 2122, 11/15/16 1258

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0568

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division	
NY Lab ID No.: 10795	New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland	
NY Lab ID No: 12006	New York State Department of Health
PA DEP ID: 68-04863	Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield  
Division Manager  
11/20/2016 14:00

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

3821 Buck Drive  
 Cordland NY 13045  
 Phone: (607)753-3403 Fax: (607)753-3415  
 NY #10795, EPA #NY00935

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

**Sample must be returned on ice**  
 MNY Workorder #

<b>Client Information</b>		<b>Billing/Invoice:</b>	
<b>ONC BOCES</b> 31 Center Street Oneonta, NY 13820 <b>Josh Reiss</b> <b>Roxbury Schools</b>		ONC BOCES	
Quote ID:	PO#	Date Req.:	
Rush TAT Bus. Days: < 2 2-5 5-7 7-10			
Carbon Copy: Yes			
Email Results: Yes			
Fax Results: Yes			

Sample Information			Matrix		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Type	Number of Containers for Analysis Requested	Comments/Field Data	Ice:	YES NO	
1 5-1 Kitchen Sink	9/22/16	6:15 am	Grab	1		Cooler:	YES NO	
2 5-2 Dishroom sink w/ spraye	9/22/16	6:16 am				Sample Temp:	YES NO	
3 5-3 Dishroom faucet sprayer	9/22/16	6:18 am				Cooler Seal:	YES NO	
4 5-4 Kitchen Rest Room sink	9/22/16	6:20 am				Pickup:	YES NO	
5 5-5 Corchus ofline bathroom sink	9/22/16	6:23 am				Dropoff:	C W	
6 5-6 Girls locker room sink	9/22/16	6:25 am				Accepted?	YES NO	
7 5-7 Coach Farnell's bathroom sink	9/22/16	6:30 am				Container Material		
8 5-8 Room # 102 sink	9/22/16	6:33 am				Container Size (in ml)		
9 5-9 Room # 104 sink	9/22/16	6:35 am				Preservative		
10 5-10 Room # 103 sink	9/22/16	6:30 am						
11 5-11 Room # 103 Bathroom sink	9/22/16	6:40						
12 5-12 Room # 109 Faculty	9/22/16	6:45						
13 5-13 Room # 109 Bathroom	9/22/16	6:48						
14 5-14 Room # 117	9/22/16	6:50						
15 5-15 Nurses Ice maker	9/22/16	6:55						
16 5-16 First Floor Old Boys Bathroom	9/22/16	7:00						
17 5-17 Room # 244 Home Ec Green	9/22/16	7:04						
18 5-18 Room # 244 Home Ec Yellow	9/22/16	7:08						
19 5-19 Room # 202 Bathroom	9/22/16	7:08						
20 5-20 2R Staff Bathroom	9/22/16	7:10						



J6J0568

Sampled:	Alan Davis	RCS	9/22/16	
Received:	Eric Mousaw	Microbac	10/5/16	0844
Received:				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795,EPA #NY00935

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

**Samples must be returned on ice**  
 MNY Workorder #

<b>Client Information</b>		<b>Billing/Invoice:</b>	
Name: <b>ONC BOCES</b>		ONC BOCES	
Address: 31 Center Street Oneonta, NY 13820			
Contact: <b>Josh Reiss</b>			
Project: <b>Roxbury Schools</b>			
Quote ID: _____		PO# _____	
Rush TAT Bus. Days: <2 2-5 5-7 7-10		Date Req.: _____	
Carbon Copy: Yes			
Email Results: Yes			
Fax Results: Yes			

Sample Information			Matrix		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Type	Number of Containers for Analysis Requested	Comments/Field Data	Ice:	YES	NO
1 S-21 Room # 240 Bathroom	9/22/16	7:12 AM	Grab	1		Cooler:	YES	NO
2 S-22 2R Girls Bathroom	9/22/16	7:15 AM				Sample Temp:	YES	NO
3 S-23 Room # 116 Bath	9/26/16	6:30 AM				Cooler Seal:	YES	NO
4 S-24 Room # 111 Girls Bath	9/26/16	6:32 AM				Pickup:	YES	NO
5 S-25 Room # 111 Bathroom	9/26/16	6:33 AM				Dropoff:	C	W
6 S-26 Room # 107 Bakery	9/26/16	6:35 AM				Accepted?	YES	NO
7 S-27 Room # 107 Bathroom	9/26/16	6:38 AM				Container Material		
8 S-28 Room # 218 Erin Lyke	9/26/16	6:42 AM				Container Size (in MI)		
9 S-29 Room # 221	9/26/16	6:50 AM				Preservative		
10 S-30 First Floor older Men	9/26/16	6:55 AM						
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								

Print Name and Company		Date/Time	Comments
Sampled: Alan Davis RCS		9/22/16	
Received: Eric Monson Microbac		9/26/16	
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.